



valid until: October 2, 2030

Cleanroom (atmospheric)

## Single product Hygienic Design

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

**Fraunhofer**  
**TESTED<sup>®</sup>**  
**DEVICE**

DYNACO EUROPE NV

Dynaco D-313 CL4

**Report No. DY 2508-1659**

## Qualification Certificate

This is to certify that the product mentioned above, provided by

**DYNACO EUROPE NV**  
Moorsel, Belgium

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number DY 2508-1659.

The door Dynaco Europe D-313 CL4 (color curtain: white) is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

**Suitability**

**up to GMP Class C**


However, this only applies to the tested system in a resting state; an overall assessment of the manufacturing environment would need to be made after its installation.

DY 2508-1659  
Report No. first document

Stuttgart, October 2, 2025  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



**Fraunhofer**  
IPA